

November 12, 2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
Docket No.: 50-293
License No.: DPR-35

Revised Submittal Schedule for Supplement to the LER 2013-002-00,
SRV-3B Safety Relief Valve Declared Inoperable Due to Leakage and
Setpoint Drift

- REFERENCE:**
1. LER 2013-002-00, "SRV-3B Safety Relief valve Declared Inoperable Due to Leakage and Setpoint Drift", dated March 31, 2013
 2. 10 CFR Part 21 Report, "Notification of a Defect, Bellows Failure", Curtis Wright Flow Control Company (Target Rock) Letter NID # 13307, dated June 17, 2013

LETTER NUMBER: 2.13.089

Dear Sir or Madam:

Licensee Event Report (LER) 2013-002-00, "SRV-3B Safety Relief Valve Declared Inoperable Due to Leakage and Setpoint Drift" was submitted on March 31, 2013 (Reference 1); with a target schedule of September 30, 2013 to submit a Supplement to the LER, after completing the root cause analysis.

Since then the vendor (Target Rock) has issued a 10 CFR Part 21 Notification, (Reference 2) confirming defects in safety relief valve bellows. Entergy is incorporating the information related to the reported defect into the root cause analysis. Due to the recent refueling outage, emergent plant events, and vendor 10 CFR, Part 21 Notification, Pilgrim resources were diverted to address the emergent work activities. As such, the review and approval of the SRV-3B root cause incorporating the vendor Part 21 Notification and the lessons learned from the events is taking longer time than expected. Accordingly, the LER Supplement is expected to be submitted by February 14, 2014.

The revised submittal schedule was discussed with the NRC/NRR Project Manager.


This letter contains no commitments.

IE22
NRD



Please do not hesitate to contact me at (508) 830-8403, if there are any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Joseph R. Lynch", followed by a horizontal line.

Joseph R. Lynch,
Manager, Pilgrim Licensing

cc: Mr. William M. Dean
Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
2100 Renaissance Blvd., Suite 100
King of Prussia, PA 19406-2713

Ms. Nadiyah Morgan, Project Manager
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
One White Flint North
Mail Stop O-8-C2A
11555 Rockville Pike
Rockville, MD. 20852-2738

INPO Records
700 Galleria Parkway
Atlanta, GA 30399-5957

USNRC Senior Resident Inspector
Pilgrim Nuclear Power Station